



PURCHASING DEPARTMENT

Johnna M. Allen, Director
Randy E. Self, Purchasing Agent
Gina Brown, Buyer I

ADDENDUM I
QUESTIONS AND ANSWERS

1. Do you have detailed prints of existing structure? **No**
2. The spec mentions that the new scoreboard/display needs to be compatible with current sound system. Can they provide us with information about the current sound system? **The current system has XLR Output, has a balanced line output into sound system, and SHURE Mixer Crown Amplification.**
3. Please confirm the top approximately 10' is a video display (viewing area of 10'H x 36'W) and the lower approximately 10' is the scoreboard. **We are open to any options offered, however, we prefer to use existing support if possible.**
4. ELECTRICAL QUESTIONS:-Is there an existing panel that would have the capacity for the added load of the new display? It will need approx 80 amps of 120/208 volt single phase power. **Yes.**
5. Is there an existing raceway for the new power? **Yes, use the existing.**
6. Is there an existing raceway from the scoreboard to the press box that will accommodate the fiber optic cable? **Yes, use the existing.**

7. The scope calls for 120 volts for "trumpet horns". What will control these horns? I assume they need a button or something in the press box. Is this circuit already in place? **No, it is needed.**

8. It states that the sound system is not included in this scope, are there any speakers on the existing structure that will need to be removed and reinstalled? If so, who will be responsible? **No should not be. If so, contractor will be responsible for removing/installing.**

9. When we take down the existing scoreboard, display, and panels, will we be responsible for disposing of these items? Or will we leave them at the Stadium for the City to deal with? **The disposal will be the responsibility of the contractor.**

Thank you,

Johnna M. Allen
Purchasing Director