

Pump Houses	Scada	HP	Volt	Amp	RPM	Phase
Armuchee Trail	No	2	230	13.2		1
Bells Ferry	Yes	30	460	76	1755	3
Burnett Ferry	Yes	10	230	63	1760	3
Filter Plant	Yes					
Fulton Well	Yes	100	460	114	1785	3
HWY 27	Yes	75	460	186	1775	3
HWY 53	Yes	20	460	47	1785	3
HWY 156	Yes	15	460	35	3556	3
HWY 411	Yes	75	460	91.5	1770	3
Kent Drive	Yes	15	460	44	3550	3
Kingston Well	Yes	30	460	82	3450	3
Midway	Yes	25	230	63	1760	3
Moran Lake	No	3	230	12.5	1780	1
Morgan Dairy	Yes	50	460	58	3525	3
Old Mill Spring	Yes	100	460	234	1760	3
Parrish Drive	Yes	15	230	39	1760	3
Ramblewood	No	5	240	24	3500	3
Raw Water Creek	Yes	75	460	94	1750	3
Rockdale	No	3	230	12.5	1780	1
Shorter Industrial	Yes	25	460	62	1775	3
Texas Valley	Yes	20	460	47.2	3510	3
Wildwood ????	No	1.5	230	9.7	1770	3
White Oak Trail	Yes	60	460	82	1760	3