



PURCHASING DEPARTMENT

Becky Smyth, Director
Jackson Abercrombie, Purchasing Agent
Gina Brown, Buyer
Kaitlin Baker, Buyer

ADDENDUM I
QUESTIONS AND ANSWERS

1. Is the City of Rome supplying the wooden utility pole for Heritage Park? What is the size in height and diameter that will be supplied or required?

There is a change at the Heritage park location. The pole that is there now will be able to be utilized. So all the park equipment will be located on that pole. The power there comes from the existing building so no assistance will be needed from Georgia Power.

2. What is the purpose for the fiber at the mausoleum and where does it connect to?

There is no fiber at the mausoleum. That location is connected by an Ethernet run (copper) to the terrace pole, then a wireless connection from there to the mausoleum.

3. On Pole 6, what is the distance to the existing Georgia Power Pole?

There is a change at the Heritage park location. The pole that is there now will be able to be utilized. So all the park equipment will be located on that pole. The power there comes from the existing building so no assistance will be needed from Georgia Power.

4. What form or method of transition is to be used for the aerial fiber on the poles and the outdoor fiber from the office and who provides that connectivity?

The vendor can either terminate into a box on the pole and run conduit out to another box at the endpoint or go down the pole directly into conduit out to the box at the endpoint.

5. What is the bolt base diameter of the decorative poles, center line to center line for mounting?
Does the city supply the J Bolts for the decorative poles?

The bolts are not included however the specs for the bolts are listed on the cut sheet details. The anchor bolt detail picture show the measurements for the bases. 20 in base.

Thank you,

Becky Smyth
Purchasing Director