



**PURCHASING DEPARTMENT**

Becky Smyth, Director  
Jackson Abercrombie, Purchasing Agent  
Gina Brown, Buyer  
Angela Devine, Buyer

**ADDENDUM 2**  
**QUESTIONS AND ANSWERS**

1. Will the client accept a substitution from Duro-Last PVC 50 mil to Firestone PVC 50 Mil?  
The use of brand name does not indicate a preference for that brand. It is intended to establish a level of quality, function, and reliability. If there are any exceptions to the bid specs, please mark it as an exception and explain the substitute.
2. Under section 1.9 Warranty section 2. b “No Exclusions for incidental or consequential damages “is only offered by the named manufactures, other manufacture does not exclude this, but is covered under the MFG insurance coverage. Is the intent to make this a single source manufacture/product from the listed manufacture?  
If there are any exceptions to the bid specs, please mark it as an exception and explain the substitute.
3. Are we to mechanically attach the new roofing system on top of the existing roofing system or are we to remove the current system and reinstall a completely new roofing system from the metal deck up.  
Contractors will only be asked to remove the current roof in places that have insulation damage. This will not be a complete tear off and roof replacement. In places that have no insulation damage, the roof will be installed over the existing roof.
4. I understand that Dura-Last is an approved manufacturer for this project, as well as those that meet or exceed the referenced product. Can you please confirm that John Mansville and Firestone are acceptable manufacturers given that the product is acceptable in comparison to Dura-Last?  
The use of brand name does not indicate a preference for that brand. It is intended to establish a level of quality, function, and reliability. If there are any exceptions to the bid specs, please mark it as an exception and explain the substitute.
5. What are the work hours/days approved for this project each week?  
All work must be completed by **February 1, 2021**, Weekend work may be necessary to complete the project within the timeframe. Should the project be incomplete on **February 1,**

**2021**, the contractor will be charged \$200.00 per day penalty for not completing the project on time.

Thank you,

Becky Smyth  
Purchasing Director